

FIRE SAFETY CERTIFICATE

No. Ref :- No 121/SE/Narsingi Municipality Dated: 14/6/2023

Certified that the S.M.P Model High School (name of the building or premises) at H. NO: 7-46, ... Sairam nagar, Hydershakote, Gandipet (M) (address) comprised of basement(s) and (upper floors) owned/ occupied by S.M.P Model High School (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 13.06.2023 (date of inspection) in the presence of School Management (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes Mont to X (X/ XII) With effect from for a period of year in accordance with rule and subject to compliance of specific conditions as appended:-

1. Hydrant and fixed installations are in working condition
2. Both the stair cases are available (internal/external)
3. 20,000 litres of water tank available in emergency
4. Set backs are available as per NOC

Issued on (date of issue) at (place) by

*Strike out whichever is not applicable.

Signature with Seal:

Name

Designation

Name & Address of Department/ Office:



To
S.M.P Model High School
Sairam nagar, Hydershakote, Gandipet (M), R.R. dist. Hyd.
 (Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand to be checked found in working conditions
 (reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Principal
 S.M.P. MODEL HIGH SCHOOL
 Hydershakote, Hyderabad.

For S.M.P. MODEL HIGH SCHOOL

 Correspondent